

Contents

1	HV Cable World Statistics and some Large Installations	1
1.1	Introduction	1
1.2	Statistics of Cable Installed Lengths	3
1.3	Large Installations of EHV Cable Systems	7
1.4	Land and Submarine 150 kV AC Cable Link Sardinia–Corsica: SAR.CO	7
1.5	The Madrid “Barajas” Airport Project (Spain)	11
1.5.1	Milestones of the Barajas Project	12
1.5.2	Technical Characteristics of the Link	12
1.5.3	Tunnel and Earthing System Characteristics	12
1.5.4	Power EHV Cables	14
1.5.5	Cable Laying in the Tunnel	16
1.5.6	The Transition Compounds and Protection Schemes	17
1.6	380 kV Double-Circuit Cable of Mixed Line Turbigo–Rho (Italy)	19
1.6.1	Milestones of the Turbigo–Rho Project	19
1.6.2	The Undergrounding Link of the Turbigo–Rho Mixed Line	20
1.6.3	Power EHV Cables	21
1.7	Cable Laying	23
1.7.1	The Transition Compounds and Protection Schemes	25
	References	27
2	The Positive Sequence Model of Symmetrical Lines	29
2.1	Introduction	29
2.2	The Transmission Matrix of a Uniform Line	29
2.3	Computation of Single-Core Cable Kilometric Parameters	33
2.3.1	Computation of r (Cable)	33
2.3.2	Computation of ℓ (Cable)	34
2.3.3	Computation of c (Cable)	35
2.3.4	Computation of g (Cable)	36
2.4	Computation of GIL Kilometric Parameters	37
2.4.1	Computation of GIL Apparent Kilometric Resistance r	38

2.4.2	Computation of GIL Kilometric Inductance ℓ	39
2.4.3	The Computation of GIL Kilometric Capacitance c	41
2.4.4	Computation of GIL Kilometric Shunt Conductance g	41
2.5	Some Other Matrix Relations Deriving from the Fundamental One	41
2.6	Cascade Connections of Two Port Networks (TPN)	42
2.7	Parallel Connection of Equal Two Port Circuits Thermally and Electrically Decoupled	43
2.8	The Shunt Reactive Compensation	45
2.8.1	The Uniformly Distributed Compensation	45
2.8.2	The Lumped Compensation	46
	References	48
3	Operating Capability of Long AC EHV Power Cables	49
3.1	Introduction	49
3.2	The Basic Constraints	49
3.3	First Analysis: $\underline{U}_{0S}(\delta)$, $\underline{I}_R$ Constrained	52
3.4	Second Analysis: $\underline{U}_{0S}(\vartheta)$, $\underline{I}_S$ Constrained	54
3.5	Voltages and Currents Along the Cable	55
3.6	Power Values Compatible with Basic Constraints and with Voltage Levels at the Receiving-End	57
3.7	No-Load Energization and De-Energization	60
3.8	Power Capability Charts	63
3.8.1	Theoretical Limits of the Length d	70
3.9	Steady State Regimes Within Power Areas	70
3.9.1	Enhanced Capability Charts	72
3.9.2	Application of Ossanna's Method	75
3.10	Cables with Gas Insulation (GILs)	78
3.11	Regimes with $U_{0S} \neq 230$ kV	80
3.12	"Receiving Area" and "Sending Area" as Set Intersection	80
3.12.1	The Determination of the Receiving Area as Set Intersection	81
3.12.2	The Determination of the Sending Area as Set Intersection	82
3.13	The Analysis Along the Cable with Lumped Shunt Compensation	82
3.14	Conclusions	86
	References	86
4	Operating Capability of AC EHV Mixed Lines with Overhead and Cables Links	89
4.1	Introduction	89
4.2	Mixed Lines: OHL–UGC–OHL	90
4.3	The Transmission Matrices for the System Study	92
4.4	First Analysis	92
4.5	Second Analysis	94
4.6	The Capability Charts	96
4.6.1	Phase Voltage Levels at R	99
4.7	No-Load Energization and De-Energization	99

4.8	The Use of Capability Charts as a Guide	104
4.9	“Receiving Area” and “Sending Area” as Intersections of Sets	110
4.10	Analysis Completion	112
4.10.1	Analysis Completion by Means of Ossanna’s Method and Matrix Algorithms	112
4.11	Circuital Considerations	113
4.11.1	The Three Matrices $\underline{N}_{H1}$, $\underline{N}_{S1}$, $\underline{N}_{R1}$	114
4.11.2	The Elements of $\underline{N}_{H1}$	114
4.11.3	The Matrix $\underline{N}_{S1}$	116
4.11.4	The Matrix $\underline{N}_{R1}$	116
4.11.5	The Matrices $\underline{N}_{K2}$, $\underline{N}_{S2}$, $\underline{N}_{R2}$	117
4.12	Conclusions	118
	References	118
5	Multiconductor Analysis of UGC	119
5.1	Introduction	119
5.2	Multiconductor Cell of Three Single-Core Cables Lines	120
5.2.1	The Admittance Matrix $\underline{Y}_{\Delta}$ to Model the Elementary Cell ..	122
5.2.2	Computation of $\underline{Z}_L$ by Means of Simplified Carson–Clem Formulae	123
5.2.3	Computation of $\underline{Z}_L$ by Means of Complete Carson Formulae	123
5.2.4	Computation of $\underline{Z}_L$ After Wedepohl	124
5.2.5	Computation of $\underline{Y}_{T\Delta}$	124
5.3	Transposition Joints Modelling: $\underline{Y}_J$	126
5.4	Earthing of Sheaths and Insertion of Possible Shunt Reactors: $\underline{Y}_E$; $\underline{Y}_{E\bar{g}}$	127
5.5	The Multiconductor Supply Model at the Sending-End	129
5.6	Equivalent Receiving-End Matrix for Load Modelling	131
5.7	The Cascade Composition of Blocks Modelled by “Admittance Partitioned Matrices”: A First, Simple Circuit	131
5.7.1	The Introduction of Other Blocks in the First Simple Circuit and the Steady State Analysis	133
5.7.2	The No-Load Subtransient Energization Analysis	135
5.8	The Admittance Matrix Equivalent to k Blocks in Cascade Connections	135
5.9	Application of Multiconductor Analysis to the System “Cable #b, 60 km” Already Studied in Chapter 3 with Simplified Criteria (see Figures 3.21 and 3.36)	137
5.9.1	Comparisons with Other Methods	145
5.10	Conclusions	146
	References	147

6 A Comparative Procedure for AC OHL and UGC Overall Cost 149

6.1 Introduction 149

6.2 OHL and UGC in the Comparative Procedure 150

6.3 The Capital Costs of OHL and UGC 154

6.4 Energy Losses and Their Actual Cost 154

6.5 The Burden on Territory 158

6.6 The Visual Impact 162

6.7 Operation and Maintenance (O&M) Costs 162

6.8 Dismantling or Decommissioning Cost 163

6.9 The Cost of UGC Shunt Reactive Compensation 163

6.10 Two Case Studies: #a1 vs. 2#c1 with $d = 10$ km 166

6.10.1 First Case Study with Duration Curve of Figure 6.14a 166

6.10.2 Second Case Study with Duration Curve of Figure 6.14b . . . 167

6.10.3 Sensitivity to the Principal Parameters 168

6.11 Case Study of Section 6.9 with Duration Curve of Figure 6.14a . . . 169

6.12 Conclusion 170

References 170

Index 173

<http://www.springer.com/978-1-84882-866-7>

EHV AC Undergrounding Electrical Power
Performance and Planning

Benato, R.; Paolucci, A.

2010, XIV, 175 p. 153 illus., Hardcover

ISBN: 978-1-84882-866-7