

Contents

Part I AC IT Systems

1 General Characteristics	3
1.1 AC IT Systems Circuit Diagrams	3
1.2 Phase-to-Ground Voltages Determination in AC IT Systems	4
1.2.1 Single-Phase Systems	4
1.2.2 Three-Phase Systems	6
1.3 Ground Fault and Leakage Currents Calculation	8
1.3.1 Single-Phase Networks	8
1.3.2 Three-Phase Networks	11
2 Ground Insulation Measurement in AC IT Systems	15
2.1 General Information	15
2.1.1 Spatial Distribution of Insulation Resistance: Network's Insulation Equivalent Circuit	15
2.2 Insulation Parameters Determination in Single-Phase Networks	16
2.2.1 De-energized Networks	16
2.2.2 Live Networks	19
2.3 Insulation Parameters Determination in Live Three-Phase Networks	21
2.3.1 Insulation Equivalent Resistance and Capacitance Values Determination	21
2.3.2 Insulation Resistance and Capacitance Determination for Single Phases	24
2.4 Unconventional Measurement Methods	29
2.4.1 Periodical Measurement of Insulation Parameters	29
2.4.2 Devices and Systems for Ground Fault, Earth Leakage and Shock Currents Measurement	32
2.5 Influence of Insulation Parameters on Possible Ground Fault, Electric Shock and Ground Leakage Currents Levels	35
2.5.1 Assessment of Ground Fault and Ground Leakage Currents	35
2.5.2 Assessment of Power Losses in Insulation	36

2.5.3	Electric Shock Hazard Assessment	37
2.6	Ground Fault Current Compensation	38
	References	41
3	Insulation Monitoring Systems	43
3.1	Visual Signalization Systems	43
3.2	Other Systems of Continuous Insulation Monitoring	45
3.2.1	Phase Voltages Monitoring	45
3.2.2	Zero-Sequence Voltage Component Monitoring	46
3.2.3	Residual Current Monitoring	48
3.2.4	Underimpedance System	52
4	Systems of Insulation Resistance Continuous Measurement	57
4.1	Measurement Circuits with Test Direct Current	57
4.2	Measuring Circuits with Diode Rectifier	58
4.2.1	Star Connected Diode Rectifier	58
4.2.2	Diode Bridge Rectifier	62
4.2.3	Other Rectifier Based Measuring Circuits	64
4.3	Measurement Method with an Auxiliary Rectangular Voltage Source	67
4.3.1	Examples of Application	68
4.4	Measurement with Use of Auxiliary AC Voltage	69
4.4.1	Application Example	71
	References	71
 Part II DC IT Systems		
5	Equivalent Circuit Diagrams of DC Networks	75
5.1	DC Network Simplified Circuit Diagram	75
5.2	Equivalent Circuit Diagrams of Batteries	77
	Reference	81
6	Insulation Resistance Measurement Methods	83
6.1	Traditional Methods of Periodical Measurement of Insulation Resistance in Live Networks	83
6.2	Other Analytical Methods	86
6.3	Unconventional Methods of Insulation Resistance Measurement	87
6.4	Evaluation of Errors of Analytical Methods	90
7	Devices and Systems for Insulation Deterioration Alarming	93
7.1	Visual Signaling of Insulation Resistance Level	93
7.2	Simple Systems of Continuous Insulation Monitoring	94
	Reference	98

8	Modern Methods of Continuous Insulation Measurement	99
8.1	Measurements with Superimposed AC Test Voltage	99
8.2	Commutation Method	100
8.2.1	Example of Application	101
8.2.2	Determination of Insulation Equivalent Resistance of DC Network and Its Single Lines	102
8.2.3	Example of Application	104
8.3	“Pulse” Test Voltage Method	105
8.3.1	An Example of Application	106
8.4	Unconventional Methods of Insulation Resistance Monitoring	108
8.4.1	Insulation Supervision with Insulation Leakage Resistance Control	108
8.4.2	Method of Auxiliary Voltage “Triangle” Pulses	109
8.4.3	System of Automatic Insulation-to-Ground Capacitance Compensation	109
	References	111
9	Ground Fault, Leakage and Electric Shock Currents in DC IT Systems	113
9.1	Time Function of Ground Fault Current	113
9.2	Measurements of Maximum and Steady-State Magnitudes of Earth Fault Current	115
9.3	Earth Leakage Currents	118
9.3.1	Calculations	118
9.3.2	Electric Shock Hazard Assessment	120
9.4	Leakage Current Measurements	122
9.4.1	Periodic Measurements	122
9.4.2	Continuous Measurements	123
9.5	Earth Fault and Shock Currents Measurement	124
9.5.1	Earth Fault and Shock Currents Measurements in Network Models	124
9.5.2	Earth Fault and Shock Currents Measurements in Live Networks	125
9.6	Network-to-Ground Capacitance Determination	126
	References	128

Part III AC and DC IT Systems

10	Effects of Insulation Failures	131
10.1	Reasons of Insulation Failures	131
10.2	Effects of Network Insulation Failures	132
10.3	Misoperation of Devices	133
10.4	Prevention of Devices Misoperation	139
10.4.1	Device Coil Shunted by Resistor	139

10.4.2	Device Coil Shunted by Other Elements	140
10.4.3	Disconnection of Both Terminals of Device Coil	141
10.4.4	Coil Shorting by NC Contact	141
10.4.5	Limitation of Total Conductor-to-Conductor and Conductor-to-Ground Capacitances	142
10.4.6	Insulation Resistance Control by Grounding Through Resistors	143
	Reference.	144
11	Insulation Monitors Settings Selection.	145
11.1	General	145
11.2	Regulations Requirements for DC Systems	146
11.3	Modified Approach for DC IT Networks	147
11.3.1	Shock and Fire Hazard Assessment	147
11.3.2	Misoperation of Devices in DC Circuits	148
11.3.3	Examples of Practical Checking of Insulation Condition Assessment Criteria	150
11.3.4	Graphical Illustration of Insulation Conditions in DC IT Networks	152
11.4	AC Insulation Monitors Settings Selection	153
11.4.1	Simplified Approach	153
11.4.2	Electric Shock and Fire Hazard Assessment	154
11.4.3	Misoperation Risk for Devices in AC IT Auxiliary Circuits	156
11.4.4	Insulation Monitors Application for Devices Misoperation Risk Detection	157
	References	158
12	AC/DC IT Systems	159
12.1	Conductor-to-Ground Voltages	159
12.2	Earth Fault and Leakage Currents	161
12.3	Misoperation of Devices in “Mixed” Systems	163
12.4	Insulation Resistance Measurement in AC/DC IT Systems	166
12.4.1	Method of “Three Readings of a Voltmeter”	166
12.4.2	Utilization of Mean Value of Phase Voltage	167
12.4.3	Pulse Voltage Method	170
12.4.4	Auxiliary AC Voltage Method	170
12.5	Insulation Resistance Measurement in IT Systems with Frequency Converters	171
	References	172
13	Earth Fault Location in IT AC/DC Systems	173
13.1	General	173
13.2	Test Current Measurement in Fault Locating Systems	175
13.3	Traditional Earth Fault Location Systems	176

13.4 Modern Insulation Fault Location Systems 177

13.4.1 Pulse Voltage Test Signal: EDS470 (Bender) 177

13.4.2 Sinusoidal Test Current: Vigilohm (Schneider) 178

13.4.3 Saw-Like Test Voltage Pulses: IPI-1M (Elterm) 178

13.4.4 Periodical Current Pulses: AT-3000 (Amprobe). 179

References 180

Insulation Measurement and Supervision in Live AC and
DC Unearthed Systems

Olszowiec, P.

2014, XI, 180 p. 132 illus., Hardcover

ISBN: 978-3-319-07009-4